

Tender Documents

**FOR THE
PROCUREMENT OF AIR-CONDITIONERS
(SPLIT TYPE)**

**KHYBER PAKHTUNKHWA
PRIVATE SCHOOLS REGULATORY AUTHORITY
HOUSE NO. 6-D IV, PARK AVENUE
UNIVERSITY TOWN PESHAWAR**

KHYBER PAKHTUNKHWA
PRIVATE SCHOOLS REGULATORY AUTHORITY PESHAWAR

TENDER DOCUMENTS REGARDING PROVISION OF AIR CONDITIONERS

Bid Submission date: 17.05.2018 at 12.noon

Bid Opening date: 17.05.2018 at 12.30 p.m

Address: KP-PSRA House No. 6-D IV Park Avenue
University Town Peshawar

Name of firm:- _____

Address:- _____

Phone No:- _____ N.T.N No. _____

G.S.T. Registration No:- _____

1- REQUIREMENTS:-

Providing and Fixing of Split Type Air-Conditioners

Sr. No.	Parameters/ Specs	AC 1.5 Tons Split Unit (Wall Mounted)	AC 2 Tons Split Unit (Floor Standing)
1	Quantity	07	01
2	Compressor	1.5 Tons (18000 BTU)	2.0 Tons (24000 BTU)
3	Inverter Technology	Yes (G-10)	Yes
4	Heat & Cool (European Compliant)	Yes	Yes
7	Complete Copper Wiring/ Coiling/ Piping	Yes	Yes
8	Eco Friendly Refrigerant	R410A	R410A
9	Precise Temperature Control	Yes	Yes
10	Low Startup Voltage	150V	150V

TERMS AND CONDITIONS:-

1. The compressor for 1.5 ton split units shall be 18,000 BTU and for 2 ton should 24,000 BTU.
2. All the air conditioners are required to have Inverter Technology with G-10 Inverter.
3. All the air conditioners are required to have both the cooling and heating functionality and should have the ceiling cooling and floor heating function.
4. The cabinets of the air conditioners should be rust resistant and the electric boxes should be fire resistant.
5. All the air conditioners are required to have complete copper coiling, wiring and piping.
6. All the air conditioners should be compliant of the international environmental codes and should have Eco-friendly refrigerant R410A.
7. All the air conditioners should be fitted with precise temperature control technology.
8. All the air conditioners should have the low startup voltage of 150 volts and should have the operational AC potential difference of 150-260V.
9. The company will be responsible for deputing qualified personnel for installation, configuration and testing of the said project.
10. The equipment/ hardware supplied by the supplier shall be brand new and complete with all respects. Moreover, the technical staff of the vendor/ company shall be involved in installation and configuration of same equipment provided.
11. The cabling must be properly tagged/ numbered and there should not be any hanging or uncovered wire.
12. All civil work (if required) e.g. installation, excavating, digging (soft & hard), curing, tunneling, configuration and testing of the piping and cabling within the premises of KP-PSRA will be the responsibility of the vendor/ firm.
13. Any submission which fails to meet the defined minimum requirements will be disqualified.
14. Rate given in the tenders must be inclusive of all Government taxes and should be valid up to 30th June 2018.
15. Rates shall be accepted on the basis of lowest cost. Quantity can be increased or decreased as per requirements
16. Income tax and GST Registered firms are eligible to participate in the tender.
17. **2% Call Deposit** of the total cost of the goods in the shape of Pay Order or Demand Draft or CDR in the name of Managing Director KP-PSRA must be enclosed with the consolidated sealed Tender/ Quotation otherwise the tender shall be rejected.

18. After receiving acceptance letter, firm will have to execute an agreement within 3-days along with 10% of the Purchase Order as Performance Security; otherwise the call deposit/earnest money will be forfeited.
19. Delivery of and installation of the goods should be made within three days from the date of signing the agreement.
20. Incomplete tenders and over writing if any on the tender will not be accepted.
21. The bidders shall mention the number of years of the warranty period with detail of the free parts replacement and services.
22. Payment will be made after successful delivery, installation and commissioning of the goods.
23. The Purchase Committee / Competent Authority can accept or reject all tenders as per KPPRA Rules, 2014.
24. Tender must be submitted on or before 17.05.2018 **by 12 noon. Bids will be opened on the same day at 12.30 p.m**

**MANAGING DIRECTOR
KP-PSRA**

House No. 6-D IV Park Avenue
University Town Peshawar
Ph: 091-5700247/5700246